



# GREEN TECH ENVIRO SOLUTIONS

WATER & WASTE WATER TREATMENT PROJECTS & CHEMICALS

To

Date: 04/02/2018

M/s. A.J. Institute of Engineering & Technology  
NH-66, Kottara Chowki  
Mangalore-575006

**Sample Particulars:** STP treated water

**Source of Collection:** STP Outlet

**Date of Collection:** 01/02/2018

Sl.No.	Parameters	Result	Standards
1	pH value	7.3	6.5-8.5
2	BOD (mg/l)	6.5	Max 10
3	COD (mg/l)	40	Max 50
4	TSS (mg/l)	2.5	Max 10
5	Ammonical Nitrogen (mg/l)	2.8	Max 5.0
6	Total Nitrogen(mg/l)	3.0	Max 10
7	Faecal Coliform(MPN/100ml)	18	<100

**Note :** This analysis report can not be used as an evidence in the court of law.

For Greentech Enviro solutions

Authorized Signatory

Principal

A.J. Institute of Engineering & Technology  
Mangaluru - 575 006



# GREEN TECH ENVIRO SOLUTIONS

WATER & WASTE WATER TREATMENT PROJECTS & CHEMICALS

To

Date: 04/02/2019

M/s. A.J. Institute of Engineering & Technology  
NH-66, Kottara Chowki  
Mangalore-575006

Sample Particulars: STP treated water

Source of Collection: STP Outlet

Date of Collection: 01/02/2019

Sl.No.	Parameters	Result	Standards
1	pH value	6.9	6.5-8.5
2	BOD (mg/l)	8.7	Max 10
3	COD (mg/l)	45	Max 50
4	TSS (mg/l)	2.5	Max 10
5	Ammonical Nitrogen (mg/l)	3.0	Max 5.0
6	Total Nitrogen(mg/l)	2.8	Max 10
7	Faecal Coliform(MPN/100ml)	10	<100

*Note : This analysis report can not be used as an evidence in the court of law.*

For Greentech Enviro solutions

Authorized Signatory

Principal  
A.J. Institute of Engineering & Technology  
Mangaluru - 575 006



# GREEN TECH ENVIRO SOLUTIONS

WATER & WASTE WATER TREATMENT PROJECTS & CHEMICALS

To

Date: 18/02/2020

M/s. A.J. Institute of Engineering & Technology  
NH-66, Kottara Chowki  
Mangalore-575006

Sample Particulars: STP treated water

Source of Collection: STP Outlet

Date of Collection: 16/02/2020

Sl.No.	Parameters	Result	Standards
1	pH value	6.8	6.5-8.5
2	BOD (mg/l)	8.0	Max 10
3	COD (mg/l)	47	Max 50
4	TSS (mg/l)	2.2	Max 10
5	Ammonical Nitrogen (mg/l)	2.0	Max 5.0
6	Total Nitrogen(mg/l)	2.8	Max 10
7	Faecal Coliform(MPN/100ml)	15	<100

*Note : This analysis report can not be used as an evidence in the court of law.*

For Greentech Enviro solutions

Authorized Signatory

Principal  
A.J. Institute of Engineering & Technology  
Mangaluru - 575 006



# GREEN TECH ENVIRO SOLUTIONS

WATER & WASTE WATER TREATMENT PROJECTS & CHEMICALS

To

Date: 27/02/2021

M/s. A.J. Institute of Engineering & Technology  
NH-66, Kottara Chowki  
Mangalore-575006

Sample Particulars: STP treated water

Source of Collection: STP Outlet


Date of Collection: 25/02/2021

Sl.No.	Parameters	Result	Standards
1	pH	6.8	6.5-8.5
2	BOD (mg/l)	8.5	Max 10
3	COD (mg/l)	47	Max 50
4	TSS (mg/l)	3.2	Max 10
5	Ammonical Nitrogen (mg/l)	1.8	Max 5.0
6	Total Nitrogen(mg/l)	3.9	Max 10
7	Faecal Coliform(MPN/100ml)	20	<100

*Note : This analysis report can not be used as an evidence in the court of law.*

For Greentech Enviro solutions

  
Authorized Signatory

  
Principal  
A.J. Institute of Engineering & Technology  
Mangaluru - 575 006



# GREEN TECH ENVIRO SOLUTIONS

WATER & WASTE WATER TREATMENT PROJECTS & CHEMICALS

To

Date: 13/02/2022

M/s. A.J. Institute of Engineering & Technology  
NH-66, Kottara Chowki  
Mangalore-575006

Sample Particulars: STP treated water

Source of Collection: STP Outlet

Date of Collection: 10/02/2022

Sl.No.	Parameters	Result	Standards
1	pH	7.2	6.5-8.5
2	BOD (mg/l)	8.0	Max 10
3	COD (mg/l)	48	Max 50
4	TSS (mg/l)	2.8	Max 10
5	Ammonical Nitrogen (mg/l)	1.7	Max 5.0
6	Total Nitrogen(mg/l)	3.7	Max 10
7	Faecal Coliform(MPN/100ml)	18	<100

**Note : This analysis report can not be used as an evidence in the court of law.**

For Greentech Enviro solutions

Authorized Signatory

Principal

A.J. Institute of Engineering & Technology  
Mangaluru - 575 006



# GREEN TECH ENVIRO SOLUTIONS

WATER & WASTE WATER TREATMENT PROJECTS & CHEMICALS

To

Date: 1/02/2023

M/s. A.J. Institute of Engineering & Technology  
NH-66, Kottara Chowki  
Mangalore-575006

Sample Particulars: STP treated water

Source of Collection: STP Outlet

Date of Collection: 29/01/2023

Sl.No.	Parameters	Result	Standards
1	pH	6.9	6.5-8.5
2	BOD (mg/l)	6.5	Max 10
3	COD (mg/l)	43	Max 50
4	TSS (mg/l)	2.8	Max 10
5	Ammonical Nitrogen (mg/l)	1.5	Max 5.0
6	Total Nitrogen(mg/l)	4.0	Max 10
7	Faecal Coliform(MPN/100ml)	10	<100

**Note : This analysis report can not be used as an evidence in the court of law.**

For Greentech Enviro solutions

Authorized Signatory

Principal  
A.J. Institute of Engineering & Technology  
Mangaluru - 575 006